



2820 S. English Station Road - Louisville, KY 40299
 Tel: (502) 357-0132 Fax (502) 267-8379

Date: 31-May-12 TEST NO. 12-0865A


ASHRAE Standard 52.2-2007 Resistance Traverse

Filter Description

Manufacturer	ECOairflow
Filter Model	Dynamo
Part Number	N A
Generic Filter Type	Panel
Nominal Dimensions (H x W x D)	24"x24"x1"
Pocket / Pleat Quantity	Flat
Media Type	Various
Est. Gross Media Area	4 Sq/Ft
Adhesive Type	N A



Air Flow vs Resistance



Test Conditions

Test Air Temp (degrees F.)	75
Relative Humidity (%)	47
Barometric Pressure (In. Hg.)	29.38

Test Results

Air Flow (CFM)	Resistance (in WG)
295	0.02
590	0.04
885	0.07
1180	0.11
1475	0.15

Comments Tested For: ECOairflow
 Product Design Flow Rate (CFM) 1200

Approval: